

**ADDENDUM NO. 2**

**PROJECT: ORANGE COAST COLLEGE  
Technology Mechanical Controls Upgrade**  
**BID NO: 1976**  
**LOCATION: Orange Coast College, 2701 Fairview Road, Costa Mesa, CA 92626**

**NOTICE TO BIDDERS ON THE ABOVE PROJECT:**

This addendum forms a part of the contract documents and modifies the original bidding documents dated May 2010 as noted below. Please acknowledge the receipt of this addendum in the space provided on the bid proposal. Failure to do so may subject the bidder to disqualification.

This addendum consists of:

**1. BID DOCUMENTS**

1.1 The Bid Opening Date will be extended to **WEDNESDAY, MAY 5, 2010 at 2:00 p.m.** Bid documents must be received and time-stamped in the Purchasing Department, Coast Community College District, 1370 Adams Avenue, Costa Mesa, CA 92626 before 2:00 p.m. on May 5, 2010. Bids received on or after 2:00 p.m. will not be opened.

**2. REQUESTS FOR INFORMATION/CLARIFICATIONS**

2.1 Please **RESCIND** RFI response 1.1, listed on Addendum 1.

Question: Is “Honeywell WEBs Niagara AX developed by Tridium” consistent with the requirement of “Vykon Niagara AX” as specified in Section 15970-1.1A.

Revised Response: No. The intent of the Specification is to specifically provide “Vykon Niagara AX, a Java-based framework developed by Tridium.” This will provide an open automation infrastructure that will integrate the existing campus systems into a unified platform. No exceptions.

All other terms and conditions remain the same.

  
\_\_\_\_\_  
Jerry Marchbank, Assistant Director, District Facilities

April 29, 2010